

# CERTIFICATE

**Certificate holder**

**Techem Energy Services GmbH**  
**Hauptstr. 89**  
**65760 Eschborn**  
**GERMANY**

**Product**

Heat cost allocators - Appliances with electrical energy supply

**Type, Model**

FHKV radio 4 / EHKV vario 4

**Testing basis**

DIN EN 834:2013-12  
Certification scheme Heat cost allocators (2014-08)

**Mark of conformity****Registration No.**

295/15 E

**Valid until**


2021-01-31

**Right of use**

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2016-02-04

  
Dipl.-Phys. Carlo Seiser  
Certifier



# ANNEX

Page 1 of 1

<b>Certificate</b>	295/15 E dated 2016-02-04
<b>Technical Data</b>	Type: Compact and remote sensor version Readout of measured values: decentral Basic conditions: 50 °C Upper temperature limits stated t(max): 90 °C Compact device, 130 °C Remote sensor device Lower temperature limits stated t(min): 35 °C
<b>Testing laboratory/ Inspection body</b>	Universität Stuttgart Institut für GebäudeEnergetik Pfaffenwaldring 35 70569 Stuttgart GERMANY
<b>Test report(s)</b>	SD15 H001 TE dated 2015-06-26 SD15 H001 TE K.1 dated 2016-01-15

